



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2171

Customer

Facility Name: Edgewood Club

Address: 1 Pennwood Ave
Pittsburgh, PA 15218

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 8/4/25

Time: 11:24 AM

Method: Grab

Sample Final Analysis

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	1:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/4/25	11:24 AM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/4/25	11:24 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:24 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2171

Customer

Facility Name: Edgewood Club

Address: 1 Pennwood Ave
Pittsburgh, PA 15218

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 8/4/25

Time: 11:24 AM

Method: Grab

Sample Final Analysis

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	1:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/4/25	11:24 AM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/4/25	11:24 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:24 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor