



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 322

Customer

Facility Name: Upper St. Clair Rec.
Address: 1551 Mayview Road
Upper St. Clair, PA 15241

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 9/16/25
Time: 3:02 PM
Method: Grab

Sample Final Analysis

Date: 9/19/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Escherichia Coli:	Absent	Absent	9/17/25	10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/17/25	10:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/16/25	5:45 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	9/17/25	10:00 AM	SL	SM 9213C
---------------------	----------	----------	---------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.8 SU	7.2 - 7.8 SU	9/16/25	3:02 PM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/16/25	3:02 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/16/25	3:02 PM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor