



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 347

Customer

Facility Name: Wyndham Grand
Address: 600 Commonwealth Place
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/29/25
Time: 11:30 AM
Method: Grab

Sample Final Analysis

Date: 8/1/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/30/25 10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25 10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25 4:00 PM	EB	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	1/0/00 12:00 AM	0	SM 9230C
---------------------	----------	----------	-----------------	---	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	7/29/25 11:30 AM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/29/25 11:30 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25 11:30 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 347

Customer

Facility Name: Wyndham Grand
Address: 600 Commonwealth Place
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/29/25
Time: 11:30 AM
Method: Grab

Sample Final Analysis

Date: 8/1/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/30/25 10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25 10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25 4:00 PM	EB	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	1/0/00 12:00 AM	0	SM 9230C
---------------------	----------	----------	-----------------	---	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	7/29/25 11:30 AM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/29/25 11:30 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25 11:30 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor