



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-2

Lab# 452

Customer

Facility Name: Doubletree Cranberry

Address: 910 Sheraton Dr
Mars, PA 16046

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/17/25

Time: 11:00 AM

Method: Grab

Sample Final Analysis

Date: 9/19/25

Time: 2:00 PM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 9/17/25 | 3:25 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/17/25 | 3:25 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/17/25 | 3:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 9/17/25 | 11:00 AM | VH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 9/17/25 | 11:00 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/17/25 | 11:00 AM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor