



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2454

Customer

Facility Name: *Rosedale Beach*
Address: *5407 3rd St.*
Verona, PA 15147

Sample Collection

Date: *7/28/25*
Time: *12:34 PM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Baby Pool*

Sample Final Analysis

Date: *7/31/25*
Time: *9:00 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/29/25 | 9:10 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/29/25 | 9:10 AM | EB | SM 9222B |
| Standard plate count: | 180/ml | 200/ml | 7/28/25 | 2:46 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/28/25 | 12:34 PM | EH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/28/25 | 12:34 PM | EH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/28/25 | 12:34 PM | EH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2454

Customer

Facility Name: *Rosedale Beach*
Address: *5407 3rd St.*
Verona, PA 15147

Sample Collection

Date: *7/28/25*
Time: *12:34 PM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Baby Pool*

Sample Final Analysis

Date: *7/31/25*
Time: *9:00 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/29/25 | 9:10 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/29/25 | 9:10 AM | EB | SM 9222B |
| Standard plate count: | 180/ml | 200/ml | 7/28/25 | 2:46 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/28/25 | 12:34 PM | EH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/28/25 | 12:34 PM | EH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/28/25 | 12:34 PM | EH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor