



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 505

Customer

Facility Name: Riverside High School

Sample Collection

Date: 9/15/25

Address: 300 Country Club Dr.
Ellwood City, PA 16117

Time: 12:30 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 9/18/25

Source Type: Pool

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/25	10:30 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/25	10:30 AM	SL SM 9222B
Standard plate count:	0/ml	200/ml	9/15/25	5:45 PM	AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/15/25	12:30 PM	BH DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/15/25	12:30 PM	BH DPD
Turbidity:	1 NTU	1 - 2 NTU	9/15/25	12:30 PM	BH Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith

Andrea Smith, Lead Supervisor