



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N - 1**

**Lab# 453**

**Customer**

Facility Name: *Fairfield Inn Butler*

Address: *200 Fairfield Ln  
Butler, PA 16001*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *9/2/25*

Time: *3:55 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *9/5/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/25 12:00 PM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/25 12:00 PM	JC	SM 9222B
Standard plate count:	120/ml	200/ml	9/2/25 5:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	9/2/25 3:55 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	9/2/25 3:55 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/25 3:55 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor