



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 415

Laboratory Analysis Report

Customer

Facility Name: *Drury Airport*

Address: *101 Ridge Rd.*
Pittsburgh, PA 15205

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *2/17/26*
Time: *11:15 AM*
Method: *Grab*

Sample Final Analysis

Date: *2/19/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/18/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/18/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/17/26	2:31 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	2/17/26	11:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/17/26	11:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/17/26	11:15 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor