



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2726

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Felson Apts*

Date: *7/14/25*

Address: *8000 Brandt Dr.*
Cranberry, PA 16066

Time: *2:15 PM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *7/17/25*

Source Type: *Pool*

Time: *8:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	7/14/25	3:53 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/14/25	2:15 PM	ZR	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/14/25	2:15 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	2:15 PM	ZR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2726

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Felson Apts*

Date: *7/14/25*

Address: *8000 Brandt Dr.*
Cranberry, PA 16066

Time: *2:15 PM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *7/17/25*

Source Type: *Pool*

Time: *8:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	7/14/25	3:53 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/14/25	2:15 PM	ZR	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/14/25	2:15 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	2:15 PM	ZR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor