Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 235

Customer

Facility Name:	*North Allegheny H.S.*
Address:	*10375 Perry Highway* *Wexford, PA 15090*
Matrix:	*Recreational Water*
Source Type:	*Shallow End*

Sample Collection

Date:	*7/7/25*
Time:	1:16 PM
Method:	*Grab*

Sample Final Analysis

Date:	*7/10/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/7/25	1:16 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	1:16 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	1:16 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# **235**

Customer

Facility Name:	*North Allegheny H.S.*
Address:	*10375 Perry Highway*
	Wexford, PA 15090
Matrix:	*Recreational Water*
Source Type:	*Shallow End*

Sample Collection

Date:	*7/7/25*
Time:	1:16 PM
Method:	*Grab*

Sample Final Analysis

Date:	*7/10/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/7/25	1:16 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	1:16 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	1:16 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor