



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041  
**C-2**

**Lab# 446**

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Comfort Inn	Date:	12/30/25			
Address:	830 East Ohio St. Pittsburgh, PA 15222	Time:	12:00 AM			
Matrix:	Recreational Water	Method:	Grab			
Source Type:	Pool					
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	12/31/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/31/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/25	4:54 PM	SL	SM 9215B

<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
pH:	8.0 SU	7.2 - 7.8 SU	12/30/25	12:40 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/30/25	12:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/30/25	12:40 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor