



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 465

Customer

Facility Name: Towers Pool
Address: 1206 Bluff St.
Pittsburgh, PA 15282

Sample Collection

Date: 10/7/25
Time: 12:00 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool Deep

Sample Final Analysis

Date: 10/10/25
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/8/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/8/25	10:00 AM	JC	SM 9222B
Standard plate count:	570/ml	200/ml	10/7/25	4:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/7/25	12:00 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	10/7/25	12:00 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/7/25	12:00 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor