



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 221

Customer

Facility Name: *Masonic Village*

Address: *1000 Masonic Dr.*
Sewickley, PA 15143

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *10/20/25*
Time: *10:48 AM*
Method: *Grab*

Sample Final Analysis

Date: *10/23/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	10/21/25 9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/21/25 9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/20/25 5:04 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	10/21/25 10:30 AM	JC	SM 9230C
---------------------	----------	----------	-------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	10/20/25 10:48 AM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/20/25 10:48 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/20/25 10:48 AM	AMH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor