



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

S-13

Lab# 267

**Customer**

Facility Name: Ringold High School  
Address: 1 Ram Drive,  
Monongahela, Pa 15063  
Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 8/4/25  
Time: 2:30 PM  
Method: Grab

**Sample Final Analysis**

Date: 8/7/25  
Time: 11:20 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	11:50 AM	AH
Total coliforms:	0/100mls	2/100mls	8/5/25	11:50 AM	AH
Standard plate count:	0/ml	200/ml	8/4/25	5:30 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	2:30 PM	SH
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/4/25	2:30 PM	SH
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	2:30 PM	SH

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

S-13

Lab# 267

**Customer**

Facility Name: Ringold High School  
Address: 1 Ram Drive,  
Monongahela, Pa 15063  
Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 8/4/25  
Time: 2:30 PM  
Method: Grab

**Sample Final Analysis**

Date: 8/7/25  
Time: 11:20 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	11:50 AM	AH
Total coliforms:	0/100mls	2/100mls	8/5/25	11:50 AM	AH
Standard plate count:	0/ml	200/ml	8/4/25	5:30 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	2:30 PM	SH
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/4/25	2:30 PM	SH
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	2:30 PM	SH

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor