Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2183

Customer		**Sample Collection**	
Facility Name:	*Fairways of Oakmont*	*Date:*	*7/16/25*
		Time:	2:18 PM
Address:	*Fairways Drive*	*Method:*	*Grab*
	Oakmont, PA 15139		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/19/25*
		Time:	*8:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/17/25	10:10 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/17/25	10:10 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/16/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/16/25	2:18 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/16/25	2:18 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/16/25	2:18 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer			*Sample Collection*	
Facility Name:	*Fairways of Oakmont*		*Date:*	*7/16/25*
			Time:	*2:18 PM*
Address:	*Fairways Drive*		*Method:*	*Grab*
	Oakmont, PA 15139			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*7/19/25*
			Time:	*8:00 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/17/25	10:10 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/17/25	10:10 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/16/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/16/25	2:18 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/16/25	2:18 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/16/25	2:18 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor