



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 224

Customer

Facility Name: *McKeesport H.S.*

Address: *1960 Eden Park Blvd.*
McKeesport, PA 15132

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *5/29/25*
Time: *10:45 AM*
Method: *Grab*

Sample Final Analysis

Date: *5/31/25*
Time: *3:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25 6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25 6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25 6:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/29/25 10:45 AM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/29/25 10:45 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25 10:45 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 224

Customer

Facility Name: McKeesport H.S.
Address: 1960 Eden Park Blvd.
McKeesport, PA 15132

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 5/29/25
Time: 10:45 AM
Method: Grab

Sample Final Analysis

Date: 5/31/25
Time: 3:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	6:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/29/25	10:45 AM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/29/25	10:45 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	10:45 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor