



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 398

Customer

Facility Name: Oliver Bath House

Address: 38 S. 10th St.
Pittsburgh, PA 15203

Sample Collection

Date: 9/9/25
Time: 8:37 AM
Method: Grab

Sample Final Analysis

Date: 9/12/25
Time: 10:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/10/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/10/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/9/25	2:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	9/9/25	8:37 AM	CMC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/9/25	8:37 AM	CMC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/9/25	8:37 AM	CMC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)