



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2434**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Residence at the Docks*

*Date: 6/10/25*

*Address: 501 Riverfront Dr.*  
*Pittsburgh, PA 15238*

*Time: 10:40 AM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 6/13/25*

*Source Type: Pool*

*Time: 9:30 AM*

*Analyst: AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 6/11/25                     | 10:30 AM | EB             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 6/11/25                     | 10:30 AM | EB             | SM 9222B      |
| Standard plate count:      | 280/ml         | 200/ml                 | 6/10/25                     | 4:50 PM  | SL             | SM 9215B      |

| <b>Field Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|-----------------------|----------------|------------------------|------------------|----------|----------------|---------------|
| pH:                   | 7.6 SU         | 7.2 - 7.8 SU           | 6/10/25          | 10:40 AM | BH             | DPD           |
| Chlorine:             | 5.0 mg/l       | 1.0 - 5.0 mg/l         | 6/10/25          | 10:40 AM | BH             | DPD           |
| Turbidity:            | 1 NTU          | 1 - 2 NTU              | 6/10/25          | 10:40 AM | BH             | Visual        |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2434**

**Customer**

*American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Residence at the Docks*

*Date: 6/10/25*

*Address: 501 Riverfront Dr.  
Pittsburgh, PA 15238*

*Time: 10:40 AM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 6/13/25*

*Source Type: Pool*

*Time: 9:30 AM*

*Analyst: AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 6/11/25                     | 10:30 AM | EB             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 6/11/25                     | 10:30 AM | EB             | SM 9222B      |
| Standard plate count:      | 280/ml         | 200/ml                 | 6/10/25                     | 4:50 PM  | SL             | SM 9215B      |

| <b>Field Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|-----------------------|----------------|------------------------|------------------|----------|----------------|---------------|
| pH:                   | 7.6 SU         | 7.2 - 7.8 SU           | 6/10/25          | 10:40 AM | BH             | DPD           |
| Chlorine:             | 5.0 mg/l       | 1.0 - 5.0 mg/l         | 6/10/25          | 10:40 AM | BH             | DPD           |
| Turbidity:            | 1 NTU          | 1 - 2 NTU              | 6/10/25          | 10:40 AM | BH             | Visual        |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor