



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-2**

**Lab# 116**

**Customer**

Facility Name: Hampton Inn  
Address: 1247 Smallman St.  
Pittsburgh, PA 15222

**Sample Collection**

Date: 2/17/26  
Time: 10:10 AM  
Method: Grab

**Sample Final Analysis**

Date: 2/19/26  
Time: 10:30 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

| Accredited Analysis   | Results  | Reporting limit | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 2/18/26    | 10:00 AM  | JC      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 2/18/26    | 10:00 AM  | JC      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 2/17/26    | 4:05 PM   | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time | Analyst  | Method |        |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH:            | 7.0 SU   | 7.2 - 7.8 SU    | 2/17/26   | 10:10 AM | BH     | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 2/17/26   | 10:10 AM | BH     | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 2/17/26   | 10:10 AM | BH     | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor