



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 452

Customer

Facility Name: Doubletree Cranberry

Sample Collection

Date: 7/14/25

Time: 10:25 AM

Method: Grab

Address: 910 Sheraton Dr
Mars, PA 16046

Matrix: Recreational Water

Sample Final Analysis

Date: 7/17/25

Time: 8:30 AM

Analyst: #REF!

Source Type: Pool

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|--------|
| Escherichia Coli: | Absent | Absent | 7/15/25 | 9:30 AM | EB |
| Total coliforms: | 0/100mls | 2/100mls | 7/15/25 | 9:30 AM | EB |
| Standard plate count: | 0/ml | 200/ml | 7/14/25 | 3:53 PM | EB |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/14/25 | 10:25 AM | ZR |
| Chlorine: | 1.5 mg/l | 1.0 - 5.0 mg/l | 7/14/25 | 10:25 AM | ZR |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/14/25 | 10:25 AM | ZR |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 452

Customer

Facility Name: Doubletree Cranberry

Sample Collection

Date: 7/14/25

Time: 10:25 AM

Method: Grab

Address: 910 Sheraton Dr
Mars, PA 16046

Matrix: Recreational Water

Sample Final Analysis

Date: 7/17/25

Time: 8:30 AM

Analyst: #REF!

Source Type: Pool

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|--------|
| Escherichia Coli: | Absent | Absent | 7/15/25 | 9:30 AM | EB |
| Total coliforms: | 0/100mls | 2/100mls | 7/15/25 | 9:30 AM | EB |
| Standard plate count: | 0/ml | 200/ml | 7/14/25 | 3:53 PM | EB |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/14/25 | 10:25 AM | ZR |
| Chlorine: | 1.5 mg/l | 1.0 - 5.0 mg/l | 7/14/25 | 10:25 AM | ZR |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/14/25 | 10:25 AM | ZR |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".