



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 057

Customer

Facility Name: Cochran Hall

Address: 1500 Cochran Road
Pittsburgh, PA 15243

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/7/25

Time: 1:56 PM

Method: Grab

Sample Final Analysis

Date: 7/10/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25 10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25 10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25 5:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/7/25 1:56 PM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/7/25 1:56 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25 1:56 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 057

Customer

Facility Name: Cochran Hall

Address: 1500 Cochran Road
Pittsburgh, PA 15243

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/7/25

Time: 1:56 PM

Method: Grab

Sample Final Analysis

Date: 7/10/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25 10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25 10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25 5:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/7/25 1:56 PM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/7/25 1:56 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25 1:56 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor