



**1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

CP

Lab# 2443

| <u>Customer</u>       |  | <u>Sample Collection</u>     |                      |          |        |          |
|-----------------------|--|------------------------------|----------------------|----------|--------|----------|
| Facility Name:        | Riverview                                  | Date:                        | 7/21/25              |          |        |          |
| Address:              | 400 Riverview Ave.<br>Pittsburgh, PA 15214 | Time:                        | 2:15 PM              |          |        |          |
| Matrix:               | Recreational Water                         |                              | <u>Method:</u> Grab  |          |        |          |
| Source Type:          | Deep End                                   | <u>Sample Final Analysis</u> |                      |          |        |          |
|                       |  | Date:                        | 7/24/25              |          |        |          |
|                       |  | Time:                        | 10:00 AM             |          |        |          |
|                       |  | Analyst:                     | AS                   |          |        |          |
| Accredited Analysis   | Results                                    | Reporting limit              | Incubation Date/Time | Analyst  | Method |          |
| Escherichia Coli:     | Absent                                     | Absent                       | 7/22/25              | 10:00 AM | AH     | SM 9222G |
| Total coliforms:      | 0/100mls                                   | 2/100mls                     | 7/22/25              | 10:00 AM | AH     | SM 9222B |
| Standard plate count: | 0/ml                                       | 200/ml                       | 7/21/25              | 5:00 PM  | AH     | SM 9215B |
| Field Analysis        | Results                                    | Reporting limit              | Date/Time            | Analyst  | Method |          |
| pH:                   | 7.0 SU                                     | 7.2 - 7.8 SU                 | 7/21/25              | 2:15 PM  | WB     | DPD      |
| Chlorine:             | 2.0 mg/l                                   | 1.0 - 5.0 mg/l               | 7/21/25              | 2:15 PM  | WB     | DPD      |
| Turbidity:            | 1 NTU                                      | 1 - 2 NTU                    | 7/21/25              | 2:15 PM  | WB     | Visual   |

Sample comments

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor



**1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

CP

Lab# 2443

| <u>Customer</u>       |  | <u>Sample Collection</u>     |                      |
|-----------------------|--|------------------------------|----------------------|
| Facility Name:        | Riverview                                  | Date:                        | 7/21/25              |
| Address:              | 400 Riverview Ave.<br>Pittsburgh, PA 15214 | Time:                        | 2:15 PM              |
| Matrix:               | Recreational Water                         |                              | <u>Method:</u> Grab  |
| Source Type:          | Deep End                                   | <u>Sample Final Analysis</u> |                      |
| Accredited Analysis   | Results                                    | Reporting limit              | Incubation Date/Time |
| Escherichia Coli:     | Absent                                     | Absent                       | 7/22/25 10:00 AM     |
| Total coliforms:      | 0/100mls                                   | 2/100mls                     | 7/22/25 10:00 AM     |
| Standard plate count: | 0/ml                                       | 200/ml                       | 7/21/25 5:00 PM      |
| <u>Field Analysis</u> |  | Results                      | Reporting limit      |
| pH:                   | 7.0 SU                                     | 7.2 - 7.8 SU                 | 7/21/25 2:15 PM      |
| Chlorine:             | 2.0 mg/l                                   | 1.0 - 5.0 mg/l               | 7/21/25 2:15 PM      |
| Turbidity:            | 1 NTU                                      | 1 - 2 NTU                    | 7/21/25 2:15 PM      |

Sample comments

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor