



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 161

Customer

Facility Name: *Holiday Inn Express*

Address: *10 Landings Dr.*
Harmarville, PA 15238

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *10/7/25*

Time: *4:32 PM*

Method: *Grab*

Sample Final Analysis

Date: *10/10/25*

Time: *11:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/8/25	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/8/25	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/7/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/7/25	4:32 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/7/25	4:32 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/7/25	4:32 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor