

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

E - 13

Lab ID No. 02-04041

Lab# 2392

Customer Sample Collection

Facility Name: Park Swim Club Date: 8/12/25 Time: 12:55 PM

Address: College Park Dr. Method: Grab Monroeville, PA 15146

Sample Final Analysis Matrix: Recreational Water Date: 8/15/25

9:00 AM Time: Source Type: Deep End Analyst: AS

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 8/13/25 9:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 8/13/25 9:30 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 8/12/25 2:56 PM SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	7.4 SU	7.2 - 7.8 SU	8/12/25	12:55 PM	EH	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/12/25	12:55 PM	EH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	12:55 PM	EH	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

E - 13

Lab ID No. 02-04041

Lab# 2392

Customer Sample Collection

Facility Name: Park Swim Club Date: 8/12/25 Time: 12:55 PM

Address: College Park Dr. Method: Grab Monroeville, PA 15146

Sample Final Analysis Matrix: Recreational Water Date: 8/15/25

9:00 AM Time: Source Type: Deep End Analyst: AS

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 8/13/25 9:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 8/13/25 9:30 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 8/12/25 2:56 PM SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	7.4 SU	7.2 - 7.8 SU	8/12/25	12:55 PM	EH	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/12/25	12:55 PM	EH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	12:55 PM	EH	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith