



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2240**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:* Hampshire House Apt

*Date:* 6/10/25

*Address:* 195 Mt. Lebanon Blvd.  
Pittsburgh, PA 15228

*Time:* 9:21 AM

*Method:* Grab

**Sample Final Analysis**

*Matrix:* Recreational Water

*Date:* 6/13/25

*Source Type:* Pool

*Time:* 9:30 AM

*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25 10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25 10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25 4:33 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25 9:21 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/10/25 9:21 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25 9:21 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2240**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:* Hampshire House Apt

*Date:* 6/10/25

*Address:* 195 Mt. Lebanon Blvd.  
Pittsburgh, PA 15228

*Time:* 9:21 AM

*Method:* Grab

**Sample Final Analysis**

*Matrix:* Recreational Water

*Date:* 6/13/25

*Source Type:* Pool

*Time:* 9:30 AM

*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	4:33 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25	9:21 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/10/25	9:21 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	9:21 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor