



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 2153**

**Customer**

Facility Name: *Dominion Homeowners*

Address: *1484 Zenith Court*  
*Pittsburgh, PA 15241*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *8/11/25*

Time: *12:27 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *8/14/25*

Time: *9:00 AM*

Analyst: *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/12/25              | 10:30 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/12/25              | 10:30 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/11/25              | 5:20 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 8/11/25   | 12:27 PM | AF      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 8/11/25   | 12:27 PM | AF      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/11/25   | 12:27 PM | AF      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 2153**

**Customer**

Facility Name: *Dominion Homeowners*

Address: *1484 Zenith Court*  
*Pittsburgh, PA 15241*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *8/11/25*

Time: *12:27 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *8/14/25*

Time: *9:00 AM*

Analyst: *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/12/25              | 10:30 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/12/25              | 10:30 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/11/25              | 5:20 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 8/11/25   | 12:27 PM | AF      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 8/11/25   | 12:27 PM | AF      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/11/25   | 12:27 PM | AF      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor