



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2141

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Crane Village

Date: 7/21/25

Address: 651 Oaklynn Court
Pittsburgh, PA 15220

Time: 2:39 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 7/24/25

Source Type: Pool

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:30 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	2:39 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/21/25	2:39 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	2:39 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2141

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Crane Village

Date: 7/21/25

Address: 651 Oaklynn Court
Pittsburgh, PA 15220

Time: 2:39 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/24/25

Source Type: Pool

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:30 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	2:39 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/21/25	2:39 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	2:39 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor