



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041

C-1

Lab# 500

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Ditheridge House	Date:	2/17/26			
Address:	220 N. Ditheridge St Pittsburgh, PA 15213	Time:	9:28 AM			
Matrix:		Method:	Grab			
Source Type:		<u>Sample Final Analysis</u>				
Recreational Water		Date:	2/19/26			
Pool		Time:	10:30 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	2/18/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/18/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/17/26	2:31 PM	SL	SM 9215B

<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
pH:	7.5 SU	7.2 - 7.8 SU	2/17/26	9:28 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	2/17/26	9:28 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/17/26	9:28 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor