

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 12

Lab# 2233

Customer Sample Collection

Facility Name: Green Oaks C.C. Date: 6/2/25

Time: 10:57 AM Address: 5741 3rd Street Method: Grab

Verona, PA 15147

Matrix: Recreational Water Date: 6/5/25

> Time: 9:30 AM

Sample Final Analysis

Source Type: Deep End Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 6/3/25 9:15 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 6/3/25 9:15 AM ΕB SM 9222B 3:25 PM ΑН SM 9215B Standard plate count: 0/ml 200/ml 6/2/25

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	10:57 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/2/25	10:57 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	10:57 AM	EH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 12

Lab# 2233

Customer Sample Collection

Facility Name: Green Oaks C.C. Date: 6/2/25

Time: 10:57 AM Address: 5741 3rd Street Method: Grab

Verona, PA 15147

Matrix: Recreational Water Date: 6/5/25

> Time: 9:30 AM

Sample Final Analysis

Source Type: Deep End Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 6/3/25 9:15 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 6/3/25 9:15 AM ΕB SM 9222B 3:25 PM ΑН SM 9215B Standard plate count: 0/ml 200/ml 6/2/25

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	10:57 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/2/25	10:57 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	10:57 AM	EH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)