



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-3**

**Lab# 456**

**Customer**

**Facility Name:** YMCA - New Kensington  
**Address:** 800 Constitution Blvd.  
New Kensington, PA 15068

**Sample Collection**

**Date:** 12/23/25  
**Time:** 2:13 PM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Final Analysis**

**Date:** 12/26/25  
**Time:** 12:00 PM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/24/25	11:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/24/25	11:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/23/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	12/23/25	2:13 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/23/25	2:13 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/23/25	2:13 PM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor