Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer		*Sample Collection*	
Facility Name:	*Foundmore*	*Date:*	*7/14/25*
		Time:	10:31 AM
Address:	*300 Hillview Dr.*	*Method:*	*Grab*
	Ross Twp., PA 15237		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/17/25*
		Time:	*8:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	10:31 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/14/25	10:31 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	10:31 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

B & R Pools and Swim Shop

Customer		*Sample Collection*	
Facility Name:	*Foundmore*	*Date:*	*7/14/25*
		Time:	10:31 AM
Address:	*300 Hillview Dr.*	*Method:*	*Grab*
	Ross Twp., PA 15237		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/17/25*
		Time:	*8:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	10:31 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/14/25	10:31 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	10:31 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor