



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2284

Customer

Facility Name: Independence Square

Address: Lexington Dr
Aliquippa, PA 15001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/21/25

Time: 9:54 AM

Method: Grab

Sample Final Analysis

Date: 7/24/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	12:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	12:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	9:54 AM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/21/25	9:54 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	9:54 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2284

Customer

Facility Name: Independence Square

Address: Lexington Dr
Aliquippa, PA 15001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/21/25

Time: 9:54 AM

Method: Grab

Sample Final Analysis

Date: 7/24/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	12:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	12:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	9:54 AM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/21/25	9:54 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	9:54 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor