



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-2**

**Lab# 348**

**Customer**

**Facility Name:** Wyndham Grand  
**Address:** 600 Commonwealth Place  
Pittsburgh, PA 15222

**Sample Collection**

**Date:** 12/1/25  
**Time:** 12:30 PM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 12/4/25  
**Time:** 10:00 AM  
**Analyst:** AS

**Source Type:** Spa

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                       |          |          |                 |    |          |
|-----------------------|----------|----------|-----------------|----|----------|
| Escherichia Coli:     | Absent   | Absent   | 12/2/25 9:35 AM | AS | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls | 12/2/25 9:35 AM | AS | SM 9222B |
| Standard plate count: | 120/ml   | 200/ml   | 12/1/25 4:15 PM | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |                  |    |          |
|---------------------|----------|----------|------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 12/2/25 10:55 AM | AS | SM 9230C |
|---------------------|----------|----------|------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|            |          |                |                  |    |        |
|------------|----------|----------------|------------------|----|--------|
| pH:        | 7.6 SU   | 7.2 - 7.8 SU   | 12/1/25 12:30 PM | BH | DPD    |
| Chlorine:  | 0.0 mg/l | 1.0 - 5.0 mg/l | 12/1/25 12:30 PM | BH | DPD    |
| Turbidity: | 1 NTU    | 1 - 2 NTU      | 12/1/25 12:30 PM | BH | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)