



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2453

Customer

Facility Name: Rosedale Beach
Address: 5407 3rd St.
Verona, PA 15147

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 7/2/25
Time: 4:04 PM
Method: Grab

Sample Final Analysis

Date: 7/4/25
Time: 3:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/2/25	4:04 PM	CW DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/2/25	4:04 PM	CW DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	4:04 PM	CW Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2453

Customer

Facility Name: Rosedale Beach
Address: 5407 3rd St.
Verona, PA 15147

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 7/2/25
Time: 4:04 PM
Method: Grab

Sample Final Analysis

Date: 7/4/25
Time: 3:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/2/25	4:04 PM	CW DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/2/25	4:04 PM	CW DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	4:04 PM	CW Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor