



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2430

**Customer**

Facility Name: Ream  
  
Address: 321 Merrimac St.  
Pittsburgh, PA 15211

**Sample Collection**

Date: 8/12/25  
Time: 12:00 PM  
Method: Grab

**Sample Final Analysis**

Date: 8/15/25  
Time: 9:00 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:58 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/12/25	12:00 PM	WB	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/12/25	12:00 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	12:00 PM	WB	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2430

**Customer**

Facility Name: Ream  
Address: 321 Merrimac St.  
Pittsburgh, PA 15211

**Sample Collection**

Date: 8/12/25  
Time: 12:00 PM  
Method: Grab

**Sample Final Analysis**

Date: 8/15/25  
Time: 9:00 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:58 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/12/25	12:00 PM	WB	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/12/25	12:00 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	12:00 PM	WB	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor