



**Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2113

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>	
Facility Name:	Clinton Lake	Date:	6/24/25
Address:	124 Clinton Dr. Clinton, PA 15026	Time:	12:45 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

		<u>Sample Final Analysis</u>	
Facility Name:	Clinton Lake	Date:	6/27/25
Address:	124 Clinton Dr. Clinton, PA 15026	Time:	9:20 AM
Matrix:	Recreational Water	Analyst:	AS
Source Type:	Pool		

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	9:30 AM	AH SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:30 AM	AH SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:59 PM	AH SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/24/25	12:45 PM	AH DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:45 PM	AH DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:45 PM	AH Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2113

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>	
Facility Name:	Clinton Lake	Date:	6/24/25
Address:	124 Clinton Dr. Clinton, PA 15026	Time:	12:45 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

		<u>Sample Final Analysis</u>	
		Date:	6/27/25
		Time:	9:20 AM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	9:30 AM	AH SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:30 AM	AH SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:59 PM	AH SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/24/25	12:45 PM	AH DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:45 PM	AH DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:45 PM	AH Visual

Sample comments

A handwritten signature in black ink that reads "Andre Smith".

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor