



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 351

Customer

Facility Name: YMCA
Address: 5021 Freeport Rd.
Natrona Heights, PA 15065

Sample Collection

Date: 11/11/25
Time: 2:42 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool Deep

Sample Final Analysis

Date: 11/14/25
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/12/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/12/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/11/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	11/11/25	2:42 PM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/11/25	2:42 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/11/25	2:42 PM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)