



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-2**

**Lab# 296**

**Customer**

Facility Name: Steel Valley High School

Address: 3113 Main Street  
Munhall, PA 15120

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 10/6/25

Time: 8:30 AM

Method: Grab

**Sample Final Analysis**

Date: 10/9/25

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/7/25	10:20 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/7/25	10:20 AM	AS	SM 9222B
Standard plate count:	570/ml	200/ml	10/6/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	10/6/25	8:30 AM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	10/6/25	8:30 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/6/25	8:30 AM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor