



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-16

Lab# 2218

**Customer**

Facility Name: *Gables at Brickyard Hill*

Address: *1170 Lily Vue Court  
Mars, PA 16046*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *7/9/25*

Time: *4:57 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/12/25*

Time: *8:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/10/25	10:50 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	7/10/25	10:50 AM	SL SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	6:15 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/9/25	4:57 PM	CW DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/9/25	4:57 PM	CW DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	4:57 PM	CW Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-16

Lab# 2218

**Customer**

Facility Name: *Gables at Brickyard Hill*

Address: *1170 Lily Vue Court  
Mars, PA 16046*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *7/9/25*

Time: *4:57 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/12/25*

Time: *8:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/10/25	10:50 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	7/10/25	10:50 AM	SL SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	6:15 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/9/25	4:57 PM	CW DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/9/25	4:57 PM	CW DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	4:57 PM	CW Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor