



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2758

Customer

Facility Name: Seven Springs Resort

Address: 777 Waterwheel Dr.
Champion, PA 15622

Matrix: Recreational Water

Source Type: Outdoor Splash Pad

Sample Collection

Date: 5/27/25

Time: 12:00 PM

Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 9:45 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 9:45 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|-----------|-----------------|------------------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 5/27/25 12:00 PM | JC | DPD |
| Chlorine: | 10.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 12:00 PM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 12:00 PM | JC | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2758

Customer

Facility Name: Seven Springs Resort

Address: 777 Waterwheel Dr.
Champion, PA 15622

Matrix: Recreational Water

Source Type: Outdoor Splash Pad

Sample Collection

Date: 5/27/25

Time: 12:00 PM

Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 9:45 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 9:45 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|-----------|-----------------|------------------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 5/27/25 12:00 PM | JC | DPD |
| Chlorine: | 10.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 12:00 PM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 12:00 PM | JC | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor