



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 322**

**Customer**

Facility Name: Upper St. Clair Rec.  
Address: 1551 Mayview Rd.  
Pittsburgh, PA 15241

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 7/28/25  
Time: 2:08 PM  
Method: Grab

**Sample Final Analysis**

Date: 7/31/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/29/25 11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25 11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25 5:40 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/29/25 11:30 AM	EB	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	7/28/25 2:08 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/28/25 2:08 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25 2:08 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 322**

**Customer**

**Facility Name:** Upper St. Clair Rec.  
**Address:** 1551 Mayview Rd.  
Pittsburgh, PA 15241

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 7/28/25  
**Time:** 2:08 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/31/25  
**Time:** 9:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/29/25 11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25 11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25 5:40 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/29/25 11:30 AM	EB	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	7/28/25 2:08 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/28/25 2:08 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25 2:08 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor