



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 363

Customer

Facility Name: YMCA - Sewickley
Address: 625 Blackburn Rd.
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 12/9/25
Time: 4:17 PM
Method: Grab

Sample Final Analysis

Date: 12/12/25
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/10/25	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/10/25	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/9/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/9/25	4:17 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/9/25	4:17 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/9/25	4:17 PM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)