

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 125

Sample Collection Customer Facility Name: Hampton Inn Date: 6/24/25 Time: 12:00 PM 475 Johnson Rd. Method: Address: Grab Washington, PA 15301 Sample Final Analysis Matrix: Recreational Water Date: 6/27/25

Source Type: Spa Time: 9:20 AM
Analyst: AS

Accredited Analysis Results **Reporting limit Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 6/25/25 9:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 6/25/25 9:30 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 6/24/25 3:59 PM EΒ SM 9215B **Additional Analysis** Results **Reporting limit Incubation Date/Time Analyst** Method Fecal Streptococcus 0/100mls 2/100mls 6/25/25 12:10 PM EΒ SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.8 SU	7.2 - 7.8 SU	6/24/25	12:00 PM	GR	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:00 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:00 PM	GR	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 125

Sample Collection Customer Facility Name: Hampton Inn Date: 6/24/25 Time: 12:00 PM 475 Johnson Rd. Method: Address: Grab Washington, PA 15301 Sample Final Analysis Matrix: Recreational Water Date: 6/27/25

Source Type: Spa Time: 9:20 AM
Analyst: AS

Accredited Analysis Results **Reporting limit Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 6/25/25 9:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 6/25/25 9:30 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 6/24/25 3:59 PM EΒ SM 9215B **Additional Analysis** Results **Reporting limit Incubation Date/Time Analyst** Method Fecal Streptococcus 0/100mls 2/100mls 6/25/25 12:10 PM EΒ SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.8 SU	7.2 - 7.8 SU	6/24/25	12:00 PM	GR	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:00 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:00 PM	GR	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)