



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2532

Customer

Facility Name: Treesdale Comm. Pool

Address: 1 Treesdale Cmns
Gibsonia, PA 15044

Matrix: Recreational Water

Source Type: Slide

Sample Collection

Date: 5/27/25

Time: 3:10 PM

Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	3:10 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	3:10 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	3:10 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)



Andre Smith, Lead Supervisor



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2532

Customer

Facility Name: Treesdale Comm. Pool

Address: 1 Treesdale Cmns
Gibsonia, PA 15044

Matrix: Recreational Water

Source Type: Slide

Sample Collection

Date: 5/27/25

Time: 3:10 PM

Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	3:10 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	3:10 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	3:10 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)



Andre Smith, Lead Supervisor