



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 242

Customer

Facility Name: *Obama High School*

Address: *515 N. Highland Ave*
Pittsburgh, PA 15206

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *8/4/25*
Time: *9:49 AM*
Method: *Grab*

Sample Final Analysis

Date: *8/7/25*
Time: *11:20 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	8/5/25 10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	8/5/25 10:50 AM	AH	SM 9222B
Standard plate count:	0/ml	A	8/4/25 4:21 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method
pH:	7.5 SU	A	8/4/25 9:49 AM	ZS	DPD
Chlorine:	1.0 mg/l	D	8/4/25 9:49 AM	ZS	DPD
Turbidity:	1 NTU	A	8/4/25 9:49 AM	ZS	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 242

Customer

Facility Name: *Obama High School*

Address: *515 N. Highland Ave*
Pittsburgh, PA 15206

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *8/4/25*
Time: *9:49 AM*
Method: *Grab*

Sample Final Analysis

Date: *8/7/25*
Time: *11:20 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	8/5/25 10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	8/5/25 10:50 AM	AH	SM 9222B
Standard plate count:	0/ml	A	8/4/25 4:21 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method
pH:	7.5 SU	A	8/4/25 9:49 AM	ZS	DPD
Chlorine:	1.0 mg/l	D	8/4/25 9:49 AM	ZS	DPD
Turbidity:	1 NTU	A	8/4/25 9:49 AM	ZS	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor