



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2255

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Highfield Crossing*
Address: *1200 Highfield Ct.*
Bethel Park, PA 15102

Sample Collection

Date: *6/3/25*
Time: *10:50 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *6/6/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25 10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25 10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25 4:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/3/25 10:50 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/3/25 10:50 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25 10:50 AM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2255

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Highfield Crossing*
Address: *1200 Highfield Ct.*
Bethel Park, PA 15102

Sample Collection

Date: *6/3/25*
Time: *10:50 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *6/6/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25 10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25 10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25 4:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/3/25 10:50 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/3/25 10:50 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25 10:50 AM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor