



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

C-1

Lab# 044

<b>Customer</b>		<b>Sample Collection</b>				
Facility Name:	Carnegie Mellon	Date:	1/27/26			
Address:	5000 Forbes Ave. Pittsburgh, PA 15213	Time:	8:41 AM			
<b>Sample Final Analysis</b>						
Matrix:	Recreational Water	Date:	1/30/26			
Source Type:	Spa	Time:	10:30 AM			
Analyst:		Analyst:	AS			
<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	1/28/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/28/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/27/26	5:16 PM	AS	SM 9215B
<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Fecal Streptococcus	0/100mls	2/100mls	1/28/26	11:30 AM	JC	SM 9230C
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.4 SU	7.2 - 7.8 SU	1/27/26	8:41 AM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	1/27/26	8:41 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/27/26	8:41 AM	GR	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor