



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2156

Customer

Facility Name: Dormont Borough Pool

Address: 1444 Hillsdale Avenue
Pittsburgh, PA 15216

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 6/2/25

Time: 9:22 AM

Method: Grab

Sample Final Analysis

Date: 6/5/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	6:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	9:22 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/2/25	9:22 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	9:22 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2156

Customer

Facility Name: *Dormont Borough Pool*

Address: *1444 Hillsdale Avenue
Pittsburgh, PA 15216*

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *6/2/25*

Time: *9:22 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/5/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	6:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	9:22 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/2/25	9:22 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	9:22 AM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor