# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

Lab ID No. 02-04041

**SERVICE**

*Lab#  2197*

| **Customer** | | **Sample Collection** | |
|---|---|---|---|
| *Facility Name:* | *Forest Oaks* | *Date:* | *6/9/25* |
| | | *Time:* | 1:51 PM |
| *Address:* | *404 Forest Edge Ct.* | *Method:* | *Grab* |
| | *Wexford, PA 15090* | | |
| | | **Sample Final Analysis** | |
| *Matrix:* | *Recreational Water* | *Date:* | *6/12/25* |
| | | *Time:* | *9:30 AM* |
| *Source Type:* | *Pool* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 6/10/25 | 10:10 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/10/25 | 10:10 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/9/25 | 5:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.2  SU | 7.2 - 7.8 SU | 6/9/25 | 1:51 PM | MM | DPD |
| Chlorine: | 0.5 mg/l | 1.0 - 5.0 mg/l | 6/9/25 | 1:51 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/9/25 | 1:51 PM | MM | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

_____

Andre Smith, Lead Supervisor

## Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

Lab ID No. 02-04041

**SERVICE**

*Lab#  2197*

### Customer

| | | | Sample Collection | |
|---|---|---|---|---|
| Facility Name: | *Forest Oaks* | | Date: | *6/9/25* |
| | | | Time: | *1:51 PM* |
| Address: | *404 Forest Edge Ct.* | | Method: | *Grab* |
| | *Wexford, PA 15090* | | | |
| | | | **Sample Final Analysis** | |
| Matrix: | *Recreational Water* | | Date: | *6/12/25* |
| | | | Time: | *9:30 AM* |
| Source Type: | *Pool* | | Analyst: | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 6/10/25 | 10:10 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/10/25 | 10:10 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/9/25 | 5:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.2  SU | 7.2 - 7.8 SU | 6/9/25 | 1:51 PM | MM | DPD |
| Chlorine: | 0.5 mg/l | 1.0 - 5.0 mg/l | 6/9/25 | 1:51 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/9/25 | 1:51 PM | MM | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

_____

Andre Smith, Lead Supervisor