



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2252

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 6/30/25
Time: 2:23 PM
Method: Grab

Sample Final Analysis

Date: 7/3/25
Time: 9:30 AM
Analyst: AS

Facility Name: *Hidden Valley Manor*

Address: *2774 Bingham Dr.*
Upper St. Clair, PA 15241

Matrix: *Recreational Water*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25 11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25 11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25 6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/30/25 2:23 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/30/25 2:23 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25 2:23 PM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2252

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Hidden Valley Manor*
Address: *2774 Bingham Dr.*
Upper St. Clair, PA 15241

Date: 6/30/25
Time: 2:23 PM
Method: Grab

Sample Final Analysis

Matrix: *Recreational Water*
Source Type: *Pool*

Date: 7/3/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25 11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25 11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25 6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/30/25 2:23 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/30/25 2:23 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25 2:23 PM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor